

OSHA Fire Protection Checklist

To help you better analyze your workplace safety, here is a Fire Protection Checklist from OSHA.

- Is your local fire department familiar with your facility, its location and specific hazards?
- If you have a fire alarm system, is it certified as required and tested annually?
- If you have interior standpipes and valves, are they inspected regularly?
- If you have interior standpipes and valves, are they inspected regularly?
- If you have outside private fire hydrants, are they flushed at least once a year and on a routine preventive maintenance schedule?
- Are fire doors and shutters in good operating condition?
- Are fire doors and shutters unobstructed and protected against obstructions, including their counterweights?
- Are fire door and shutter fusible links in place?
- Are automatic sprinkler system water control valves, air and water pressure checked periodically as required?
- Is the maintenance of automatic sprinkler systems assigned to responsible persons or to a sprinkler contractor?
- Are sprinkler heads protected by metal guards if exposed to potential physical damage?
- Is proper clearance maintained below sprinkler heads?
- Are portable fire extinguishers provided in adequate number and type and mounted in readily accessible locations?
- Are fire extinguishers recharged regularly with this noted on the inspection tag?
- Are employees periodically instructed in the use of fire extinguishers and fire protection procedures?